

ARRANGEMENT OF THE LUMINAIRE DEVICES:

- near to every Emergency door
- near to every flight of stairs which must receive direct light.
- near to every change in level.
- on the safety signs on the exit routes lit externally
- at every change in direction.
- at every corridor crossing.
- at every safe place in which individuals converge outside

the emergency exit.

- near to every first-aid site, 5lx
- near to every fire fighting device and calling point, 5lx
- near to every evacuation device for the disabled
- near to shelters and collection points for the disabled
- near to the wc for the disabled
(near means within 2 m)

